

Wise County Public Service Authority
P.O. Box 3388
WISE, VA 24293

PRESORTED
FIRST CLASS MAIL
U.S. POSTAGE PAID
WISE COUNTY
PERMIT NO. 2

Annual Drinking Water Quality Report **SOUTH MOUNTAIN WATER SYSTEM PWSID# 1195940**

THE WISE COUNTY PSA PURCHASES WATER FROM THE TOWN OF POUND FOR YOUR SERVICE AREA. IN COMPLYING WITH EPA REGULATIONS, WE ARE FURNISHING YOU WITH THIS REPORT. Information in this report contains data collected by both the Town of Pound and the Wise County PSA.

INTRODUCTION

This Annual Drinking Water Quality Report for calendar year 2016 is designed to inform you about your drinking water quality. The Wise County PSA routinely monitors for constituents in your drinking water in accordance with Federal and State Laws.

If you have questions about this report, want additional information about any aspect of your drinking water or want to know how to participate in decisions that may affect the quality of your drinking water, please contact: **Wise County Regional Water Treatment Plant at (276) 762-0159**. You may also contact Mr. Richard Fleming - *Pound Water Plant* - (276) 796-4834

The times and location of regularly scheduled board meetings are as follows:

DATE: 2ND Tuesday of each month **TIME:** 6:00 pm **LOCATION:** Wise County PSA Office (276) 679-1520

GENERAL INFORMATION

Drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems. (5) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limits the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Source: The Town of Pound receives and treats surface water from the North Fork Reservoir. The Pound reservoir and Treatment plant are both located on the North Fork of the Pound River. Feel free to visit the Water plant or call to make arrangements for a group tour. The Virginia Department of Health conducted a source water assessment of our watershed during 2001. The North Fork Reservoir was determined to be of HIGH susceptibility to contamination, using the criteria developed by the state in its approved Source Water Assessment Program. The assessment report consists of maps showing the source water assessment area and an inventory of known land use activities of concern. The report is available by contacting Mr. Richard Fleming at the phone number given elsewhere in this drinking water quality report. The Town of Pound Council Members normally meet the third Thursday of each month at the Town Hall. If you have any comments or suggestions, please contact the Town Hall for the next scheduled Council Meeting. The Customer's input is always welcome.

DEFINITIONS

Contaminants in your drinking water are routinely monitored according to Federal and State regulations. The table on the next page shows the results of our monitoring for the period of January 1st to December 31st, 2016. In the table and elsewhere in this report you will find many terms and abbreviations you might not be familiar with. The following definitions are provided to help you better understand these terms:

Level 1 assessment - a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 assessment - a very detailed study of the waterworks to identify potential problems and determine (if possible) why an *E. coli* PMCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level, or MCL - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal, or MCLG - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity, or cloudiness, of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is monitored because it is a good indicator of the effectiveness of our filtration system.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Microbiological Contaminants

WATER QUALITY RESULTS Regulated Contaminants

Contaminant (units)	MCLG	MCL	Level Detected	Violation (Y/N)	Range	Date of Sample	Typical Source of Contamination
Trihalomethanes (ppb)	N/A	80	57	N	32 - 110	2016	By-product of drinking water disinfection
Haloacetic Acids (ppb)	NA	60	52	N	34- 74	2016	By-product of drinking water disinfection
Barium (ppm)	2	2	0.025	N	N/A	2016	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits
Xylenes (ppm)	10	10	0.0016	N	N/A	2016	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Arsenic(ppb)	0	10	0.4	N	N/A	2016	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic wastes.
Chlorine (ppm)	4.0	4.0	0.63	N	0.3 – 0.9	2016	Water additives to control microbes
Turbidity (NTU)	N/A	TT, 1 NTU max	0.2	N	N/A	2016	Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.
		TT, <0.3 NTU 95% of time	100 %	N	N/A		
Total Organic Carbon	NA	TT, MET when > or = 1	1.0	N	1.0 – 1.0	2016	Naturally present in the environment
Fluoride (ppm)	4	4	0.6	N	N/A	2016	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Lead and Copper Contaminants

Contaminant (units)	MCLG	Action Level	90 th Percentile	Date of Sample	# of Sample Sites Exceeding Action Level	Typical source of Contamination
Lead (ppb)	0	AL= 15	2	2014	0	Corrosion of household plumbing system; Erosion of natural deposits
Copper (ppm)	1.3	AL = 1.3	0.32	2014	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

VIOLATION INFORMATION

No violations in 2016.

The water quality results in the above tables are from testing done in **2016**. However, the state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

MCL's are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

VIOLATION INFORMATION

Did any MCL or TT violations occur during the year? () Yes (X) No

If yes, an explanation of the violation, including length, potential health effects, and actions we are taking to correct the violation, is as follows:

Did any monitoring, reporting, or other violations occur during the year? () Yes (X) No

If yes, an explanation of the violation, including potential adverse health effects and steps we are taking to correct the violation, is as follows:

YOUR WATER SYSTEM DID NOT RECEIVE ANY OF THESE VIOLATIONS DURING THE YEAR OF 2016.

ADDITIONAL HEALTH INFORMATION

In 2016, the Town of Pound began monitoring for Cryptosporidium in the source water (before treatment) as required by EPA's Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR). Cryptosporidium is a microscopic parasite found in surface water throughout the United States. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100 percent removal. Under the LT2ESWTR, the average Cryptosporidium concentration determines if additional treatment measures are needed. Twenty-four samples are required for analysis over a two-year period. During 2016, the average Cryptosporidium concentration was 0 oocysts per liter for the 3 samples collected. Based on the Cryptosporidium monitoring results so far and the current performance of the treatment plant, we anticipate meeting the future treatment requirements of the LT2ESWTR.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wise County Public Service Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

What Does all this mean?

As you can see by the table, our system had no violations. We're proud that your drinking water exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents, as expected, have been detected. This is normal and the EPA has determined that your water **IS SAFE** at these levels.

IF YOU DESIRE A PAPER COPY YOU CAN RECEIVE ONE AT THE WISE COUNTY PUBLIC SERVICE AUTHORITIES OFFICE.